



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24ABB318(A,W)32	17.6	10.90	13.00 <sup>(1)(2)(3)</sup>	18CDX-HW,19CDX-HW,24CDX-HW, 25CDX-HW,18CDXQ,19CDXQ, 24CDXQ,25CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,18DFCH, 24DFCH,24EVB-HW,24EVBQ, 24EVX*,18HBQ*,24HBQ*,18HBX, 24HBX,18HBX*-HW,24HBX*-HW, 18HX,19HX,24HX,25HX,19HXX, 25HXX,18MBQ**F,24MBQ**F,19UC, 24UC,25UC,19UC-HW,24UC-HW, 25UC-HW,19UCQ*,24UCQ*, 25UCQ*,19UCX,25UCX,19UCX-HW, 25UCX-HW,19UCXQ*,25UCXQ*, 24VHBQ*,24VHBX*-HW,24VHBX,
24ABB318C30	17.7	11.00	13.00 <sup>(1)(2)(3)</sup>	18CDX-HW,19CDX-HW,24CDX-HW, 25CDX-HW,18CDXQ,19CDXQ, 24CDXQ,25CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,18DFCH, 24DFCH,24EVB-HW,24EVBQ, 24EVX*,18HBQ*,24HBQ*, 18HBX*-HW,24HBX*-HW,18HBX, 24HBX,18HX,19HX,24HX,25HX, 19HXX,25HXX,18MBQ**F, 24MBQ**F,19UC,24UC,25UC, 19UC-HW,24UC-HW,25UC-HW, 19UCQ*,24UCQ*,25UCQ*,19UCX, 25UCX,19UCX-HW,25UCX-HW, 19UCXQ*,25UCXQ*,24VHBQ*, 24VHBX*-HW,24VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24ABB324(A,W)31	23.0	11.00	13.00 <sup>(1)(2)(3)</sup>	25CDX-HW,30CDX-HW,31CDX-HW, 25CDXQ,30CDXQ,31CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,24DFCH, 30DFCH,24EVB-HW,24EVBQ, 24EVX*,24HBQ*,30HBQ*, 24HBX*-HW,30HBX*-HW,24HBX, 30HBX,24HX,25HX,30HX,31HX, 25HXX,31HXX,24MBQ**F, 30MBQ**F,24UC,25UC,30UC,31UC, 24UC-HW,25UC-HW,30UC-HW, 31UC-HW,24UCQ*,25UCQ*, 30UCQ*,31UCQ*,25UCX,31UCX, 25UCX-HW,31UCX-HW,25UCXQ*, 31UCXQ*,24VHBQ*,24VHBX*-HW, 24VHBX,
24ABB324C30	22.6	10.70	13.00 <sup>(1)(2)(3)</sup>	25CDX-HW,30CDX-HW,31CDX-HW, 25CDXQ,30CDXQ,31CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,24DFCH, 30DFCH,24EVB-HW,24EVBQ, 24EVX*,24HBQ*,30HBQ*, 24HBX*-HW,30HBX*-HW,24HBX, 30HBX,25HX,30HX,31HX,25HXX, 31HXX,24MBQ**F,30MBQ**F,24UC, 25UC,30UC,31UC,24UC-HW, 25UC-HW,30UC-HW,31UC-HW, 24UCQ*,25UCQ*,30UCQ*,31UCQ*, 25UCX,31UCX,25UCX-HW, 31UCX-HW,25UCXQ*,31UCXQ*, 24VHBQ*,24VHBX*-HW,24VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24ABB330(A,W)31	27.4	10.90	13.00 <sup>(1)(2)(3)</sup>	31CDX-HW,36CDX-HW,37CDX-HW, 31CDXQ,36CDXQ,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,30DFCH, 36EVB-HW,36EVBQ,36EVX*, 30HBQ*,36HBQ*,30HBX*-HW, 36HBX*-HW,30HBX,36HBX,30HX, 31HX,36HX,37HX,31HXX,37HXX, 36HYX,30MBQ**F,36MBQ**F, 36PHYX,37RAQ,30UC,31UC,36UC, 37UC,30UC-HW,31UC-HW, 36UC-HW,37UC-HW,30UCQ*, 31UCQ*,36UCQ*,37UCQ*,31UCX, 37UCX,31UCX-HW,37UCX-HW, 31UCXQ*,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,
24ABB330C30	29.0	11.00	13.00 <sup>(1)(2)(3)</sup>	31CDX-HW,36CDX-HW,37CDX-HW, 31CDXQ,36CDXQ,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,30DFCH, 36EVB-HW,36EVBQ,36EVX*, 30HBQ*,36HBQ*,30HBX*-HW, 36HBX*-HW,30HBX,36HBX,30HX, 31HX,36HX,37HX,31HXX,37HXX, 36HYX,30MBQ**F,36MBQ**F, 36PHYX,37RAQ,30UC,31UC,36UC, 37UC,30UC-HW,31UC-HW, 36UC-HW,37UC-HW,30UCQ*, 31UCQ*,36UCQ*,37UCQ*,31UCX, 37UCX,31UCX-HW,37UCX-HW, 31UCXQ*,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24ABB336(A,W)**32	33.8	11.00	13.00 <sup>(1)(2)(3)</sup>	36CDX-HW,37CDX-HW,36CDXQ, 37CDXQ,36CLP,36CLP-AQ, 36CLP-HW,36CLX,36CLXAQ, 36CLX-HW,36EVB-HW,36EVBQ, 36EVX*,36HBQ*,36HBX*-HW, 36HBX,36HX,37HX,37HXX,36HYX, 36MBQ**F,36PHYX,37RAQ,36UC, 37UC,36UC-HW,37UC-HW,36UCQ*, 37UCQ*,37UCX,37UCX-HW, 37UCXQ*,36VHBQ*,36VHBX*-HW, 36VHBX,
24ABB336C30	34.4	10.70	13.00 <sup>(1)(2)(3)</sup>	36CDX-HW,37CDX-HW,36CDXQ, 37CDXQ,36CLP,36CLP-AQ, 36CLP-HW,36CLX,36CLXAQ, 36CLX-HW,36EVB-HW,36EVBQ, 36EVX*,36HBQ*,36HBX*-HW, 36HBX,36HX,37HX,37HXX,36HYX, 36MBQ**F,36PHYX,37RAQ,36UC, 37UC,36UC-HW,37UC-HW,36UCQ*, 37UCQ*,37UCX,37UCX-HW, 37UCXQ*,36VHBQ*,36VHBX*-HW, 36VHBX,
24ABB342(A,W)**31	41.5	11.00	13.00 <sup>(1)(2)(3)</sup>	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,48HBX*-HW,48HBX, 48HYX,48MBQ**F,48PHYX, 48VHBQ*,48VHBX*-HW,48VHBX,
24ABB342C30	40.5	10.50	13.00 <sup>(1)(2)(3)</sup>	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,48HBX*-HW,48HBX, 48HYX,48MBQ**F,48PHYX, 48VHBQ*,48VHBX*-HW,48VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24ABB348(A,W)**32	46.0	11.00	13.00 <sup>(1)(2)(3)</sup>	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,60HBQ*,48HBX*-HW, 60HBX*-HW,48HBX,60HBX,48HYX, 60HYX,60MBQ**F,48PHYX, 60PHYX,48VHBQ*,60VHBQ*, 48VHBX*-HW,60VHBX*-HW, 48VHBX,60VHBX,
24ABB348A**	46.0	11.00	13.20 <sup>(1)(2)(3)</sup>	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,60HBQ*,48HBX*-HW, 60HBX*-HW,48HBX,60HBX,48HYX, 60HYX,60MBQ**F,48PHYX, 60PHYX,48VHBQ*,60VHBQ*, 48VHBX*-HW,60VHBX*-HW, 48VHBX,60VHBX,
24ABB348C30	46.5	10.70	13.00 <sup>(1)(2)(3)</sup>	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,60HBQ*,48HBX*-HW, 60HBX*-HW,48HBX,60HBX,48HYX, 60HYX,60MBQ**F,48PHYX, 60PHYX,48VHBQ*,60VHBQ*, 48VHBX*-HW,60VHBX*-HW, 48VHBX,60VHBX,
24ABB360(A,W)32	57.5	11.00	13.00 <sup>(1)(2)(3)</sup>	60HBQ*,60HBX*-HW,60HBX, 60HYX,60MBQ**F,60PHYX, 60VHBQ*,60VHBX*-HW,60VHBX,
24ABB360A**	57.5	11.00	13.00 <sup>(1)(2)(3)</sup>	60HBQ*,60HBX*-HW,60HBX, 60HYX,60MBQ**F,60PHYX, 60VHBQ*,60VHBX*-HW,60VHBX,
24ABB360C31	59.5	11.20	13.00 <sup>(1)(2)(3)</sup>	60HBQ*,60HBX*-HW,60HBX, 60HYX,60MBQ**F,60PHYX, 60VHBQ*,60VHBX*-HW,60VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.