



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24ACB418A30	18.0	11.50	14.00 <sup>(1)(2)(3)</sup>	19CDX-HW,25CDX-HW,19CDXQ, 25CDXQ,24CLP,24CLP-AQ, 24CLP-HW,24CLX,24CLX-AQ, 24CLX-HW,24DFCH,24EVB-HW, 24EVBQ,24EVX*,18HBQ*,24HBQ*, 18HBX*-HW,24HBX*-HW,18HBX, 24HBX,19HX,25HX,19HXX,25HXX, 24MBQ**F,25UC,25UC-HW, 25UCQ*,19UCX,25UCX,19UCX-HW, 25UCX-HW,19UCXQ*,25UCXQ*, 24VHBQ*,24VHBX*-HW,24VHBX,
24ACB424A30	23.2	11.70	14.00 <sup>(1)(2)(3)</sup>	25CDX-HW,30CDX-HW,31CDX-HW, 25CDXQ,30CDXQ,31CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,24DFCH, 30DFCH,24EVB-HW,24EVBQ, 24EVX*,24HBQ*,30HBQ*, 24HBX*-HW,30HBX*-HW,24HBX, 30HBX,25HX,30HX,31HX,25HXX, 31HXX,24MBQ**F,30MBQ**F,25UC, 30UC,31UC,25UC-HW,30UC-HW, 31UC-HW,25UCQ*,30UCQ*, 31UCQ*,25UCX,31UCX,25UCX-HW, 31UCX-HW,25UCXQ*,31UCXQ*, 24VHBQ*,24VHBX*-HW,24VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24ACB430A30	29.0	11.70	14.00 <sup>(1)(2)(3)</sup>	31CDX-HW,37CDX-HW,31CDXQ, 37CDXQ,36CLP,36CLP-AQ, 36CLP-HW,36CLX,36CLXAQ, 36CLX-HW,30DFCH,36EVB-HW, 36EVBQ,36EVX*,30HBQ*,36HBQ*, 30HBX*-HW,36HBX*-HW,30HBX, 36HBX,31HX,36HX,37HX,31HXX, 37HXX,36HYX,30MBQ**F, 36MBQ**F,36PHYX,37RAQ,30UC, 31UC,36UC,37UC,30UC-HW, 31UC-HW,36UC-HW,37UC-HW, 30UCQ*,31UCQ*,36UCQ*,37UCQ*, 31UCX,37UCX,31UCX-HW, 37UCX-HW,31UCXQ*,37UCXQ*, 36VHBQ*,36VHBX*-HW,36VHBX,
24ACB436A30	35.8	12.00	14.00 <sup>(1)(2)(3)</sup>	37CDX-HW,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,36EVB-HW, 36EVBQ,36EVX*,36HBQ*, 36HBX*-HW,36HBX,37HX,37HXX, 36HYX,36MBQ**F,36PHYX,37RAQ, 37UC,37UC-HW,37UCQ*,37UCX, 37UCX-HW,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,
24ACB442A30	40.0	12.00	14.00 <sup>(1)(2)(3)</sup>	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,48HBX*-HW,48HBX, 48HYX,48PHYX,48VHBQ*, 48VHBX*-HW,48VHBX,
24ACB448A30	48.0	11.50	14.00 <sup>(1)(2)(3)</sup>	48EVB-HW,48EVBQ,48EVX*, 60HBQ*,60HBX*-HW,60HBX, 60HYX,60PHYX,60VHBQ*, 60VHBX*-HW,60VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



<b>CARRIER CONDENSING UNIT</b>	<b>MBTUH</b>	<b>EER</b>	<b>SEER</b>	<b>FIRST CO. EVAPORATOR MODELS</b>
24ACB460A31	59.0	12.00	14.00 <sup>(1)(2)(3)</sup>	60HBQ*,60HBX*-HW,60HBX, 60HYX,60PHYX,60VHBQ*, 60VHBX*-HW,60VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.