



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24APA518A31	18.3	12.00	14.00 ⁽¹⁾⁽²⁾⁽³⁾	19CDX-HW,25CDX-HW,19CDXQ, 25CDXQ,24CLP,24CLP-AQ, 24CLP-HW,24CLX,24CLX-AQ, 24CLX-HW,24DFCH,24EVB-HW, 24EVBQ,24EVX*,18HBQ*,24HBQ*, 18HBX*-HW,24HBX*-HW,18HBX, 24HBX,19HX,25HX,19HXX,25HXX, 24MBQ**F,24UC,25UC,24UC-HW, 25UC-HW,24UCQ*,25UCQ*,19UCX, 25UCX,19UCX-HW,25UCX-HW, 19UCXQ*,25UCXQ*,24VHBQ*, 24VHBX*-HW,24VHBX,
24APA524A31	23.4	12.00	14.00 ⁽¹⁾⁽²⁾⁽³⁾	31CDX-HW,31CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,24DFCH, 30DFCH,24EVB-HW,24EVBQ, 24EVX*,24HBQ*,30HBQ*, 24HBX*-HW,30HBX*-HW,24HBX, 30HBX,31HX,31HXX,30MBQ**F, 25UC,30UC,31UC,25UC-HW, 30UC-HW,31UC-HW,25UCQ*, 30UCQ*,31UCQ*,25UCX,31UCX, 25UCX-HW,31UCX-HW,25UCXQ*, 31UCXQ*,24VHBQ*,24VHBX*-HW, 24VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
24APA530A31	28.8	12.00	14.00 ⁽¹⁾⁽²⁾⁽³⁾	31CDX-HW,37CDX-HW,31CDXQ, 37CDXQ,36CLP,36CLP-AQ, 36CLP-HW,36CLX,36CLXAQ, 36CLX-HW,30DFCH,36EVB-HW, 36EVBQ,36EVX*,30HBQ*,36HBQ*, 30HBX*-HW,36HBX*-HW,30HBX, 36HBX,31HX,36HX,37HX,31HXX, 37HXX,36HYX,36MBQ**F,36PHYX, 37RAQ,31UC,37UC,31UC-HW, 37UC-HW,31UCQ*,37UCQ*,31UCX, 37UCX,31UCX-HW,37UCX-HW, 31UCXQ*,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,
24APA536A31	35.0	11.95	14.00 ⁽¹⁾⁽²⁾⁽³⁾	37CDX-HW,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,36EVB-HW, 36EVBQ,36EVX*,36HBQ*, 36HBX*-HW,36HBX,37HX,37HXX, 36HYX,36MBQ**F,36PHYX,37RAQ, 37UC,37UC-HW,37UCQ*,37UCX, 37UCX-HW,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,
24APA542A31	41.5	11.90	14.00 ⁽¹⁾⁽²⁾⁽³⁾	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,48HBX*-HW,48HBX, 48HYX,48PHYX,48VHBQ*, 48VHBX*-HW,48VHBX,
24APA560A32	58.5	11.85	14.00 ⁽¹⁾⁽²⁾⁽³⁾	60HBQ*,60HBX*-HW,60HBX, 60HYX,60PHYX,60VHBQ*, 60VHBX*-HW,60VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.