



CARRIER OUTDOOR UNIT	Cooling			Heating		FIRST CO. INDOOR UNITS
	MBTUH	EER	SEER	MBTUH	HSPF	
25HBB318(A,W)30	17.2	10.70	13.00 ⁽¹⁾⁽²⁾⁽³⁾	18.0	7.70	19CDX-HW,24CDX-HW,25CDX-HW, 19CDXQ,24CDXQ,25CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,18DFCH, 24DFCH,24EVB-HW,24EVBQ, 24EVX*,18HBQ*,24HBQ*, 18HBX*-HW,24HBX*-HW,18HBX, 24HBX,19HX,24HX,25HX,19HXX, 25HXX,18MBQ**F,24MBQ**F,19UC, 24UC,25UC,19UC-HW,24UC-HW, 25UC-HW,19UCQ*,24UCQ*, 25UCQ*,19UCX,25UCX,19UCX-HW, 25UCX-HW,19UCXQ*,25UCXQ*, 24VHBQ*,24VHBX*-HW,24VHBX,
25HBB318C31	17.6	11.00	13.00 ⁽²⁾⁽³⁾	18.0	8.00	19CDX-HW,24CDX-HW,25CDX-HW, 19CDXQ,24CDXQ,25CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,18DFCH, 24DFCH,24EVB-HW,24EVBQ, 24EVX*,18HBQ*,24HBQ*, 18HBX*-HW,24HBX*-HW,18HBX, 24HBX,19HX,24HX,25HX,19HXX, 25HXX,18MBQ**F,24MBQ**F,19UC, 24UC,25UC,19UC-HW,24UC-HW, 25UC-HW,19UCQ*,24UCQ*, 25UCQ*,19UCX,25UCX,19UCX-HW, 25UCX-HW,19UCXQ*,25UCXQ*, 24VHBQ*,24VHBX*-HW,24VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER OUTDOOR UNIT	Cooling			Heating		FIRST CO. INDOOR UNITS
	MBTUH	EER	SEER	MBTUH	HSPF	
25HBB324(A,W)30	22.6	10.50	13.00 ⁽¹⁾⁽²⁾⁽³⁾	24.0	8.20	25CDX-HW,31CDX-HW,25CDXQ, 31CDXQ,24CLP,24CLP-AQ, 24CLP-HW,24CLX,24CLX-AQ, 24CLX-HW,24DFCH,30DFCH, 24EVB-HW,24EVBQ,24EVX*, 24HBQ*,30HBQ*,24HBX*-HW, 30HBX*-HW,24HBX,30HBX,25HX, 30HX,31HX,25HXX,31HXX, 24MBQ**F,30MBQ**F,25UC,30UC, 31UC,25UC-HW,30UC-HW, 31UC-HW,25UCQ*,30UCQ*, 31UCQ*,25UCX,31UCX,25UCX-HW, 31UCX-HW,25UCXQ*,31UCXQ*, 24VHBQ*,24VHBX*-HW,24VHBX,
25HBB324C31	23.6	11.50	13.50 ⁽¹⁾⁽²⁾⁽³⁾	24.0	8.20	25CDX-HW,31CDX-HW,25CDXQ, 31CDXQ,24CLP,24CLP-AQ, 24CLP-HW,24CLX,24CLX-AQ, 24CLX-HW,24DFCH,30DFCH, 24EVB-HW,24EVBQ,24EVX*, 24HBQ*,30HBQ*,24HBX*-HW, 30HBX*-HW,24HBX,30HBX,25HX, 30HX,31HX,25HXX,31HXX, 24MBQ**F,30MBQ**F,25UC,30UC, 31UC,25UC-HW,30UC-HW, 31UC-HW,25UCQ*,30UCQ*, 31UCQ*,25UCX,31UCX,25UCX-HW, 31UCX-HW,25UCXQ*,31UCXQ*, 24VHBQ*,24VHBX*-HW,24VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER OUTDOOR UNIT	Cooling			Heating		FIRST CO. INDOOR UNITS
	MBTUH	EER	SEER	MBTUH	HSPF	
25HBB330(A,W)30	30.0	10.80	13.00 ⁽¹⁾⁽²⁾⁽³⁾	30.0	8.00	31CDX-HW,36CDX-HW,37CDX-HW, 31CDXQ,36CDXQ,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,30DFCH, 36EVB-HW,36EVBQ,36EVX*, 30HBQ*,36HBQ*,30HBX*-HW, 36HBX*-HW,30HBX,36HBX,30HX, 31HX,36HX,37HX,31HXX,37HXX, 36HYX,30MBQ**F,36MBQ**F, 36PHYX,37RAQ,30UC,31UC,36UC, 37UC,30UC-HW,31UC-HW, 36UC-HW,37UC-HW,30UCQ*, 31UCQ*,36UCQ*,37UCQ*,31UCX, 37UCX,31UCX-HW,37UCX-HW, 31UCXQ*,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,
25HBB330C31	30.0	10.80	13.00 ⁽¹⁾⁽²⁾⁽³⁾	30.0	8.00	31CDX-HW,36CDX-HW,37CDX-HW, 31CDXQ,36CDXQ,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,30DFCH, 36EVB-HW,36EVBQ,36EVX*, 30HBQ*,36HBQ*,30HBX*-HW, 36HBX*-HW,30HBX,36HBX,30HX, 31HX,36HX,37HX,31HXX,37HXX, 36HYX,30MBQ**F,36MBQ**F, 36PHYX,37RAQ,30UC,31UC,36UC, 37UC,30UC-HW,31UC-HW, 36UC-HW,37UC-HW,30UCQ*, 31UCQ*,36UCQ*,37UCQ*,31UCX, 37UCX,31UCX-HW,37UCX-HW, 31UCXQ*,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER OUTDOOR UNIT	Cooling			Heating		FIRST CO. INDOOR UNITS
	MBTUH	EER	SEER	MBTUH	HSPF	
25HBB336(A,W)30	33.8	10.50	13.00 ⁽¹⁾⁽²⁾⁽³⁾	35.4	7.80	37CDX-HW,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,36EVB-HW, 36EVBQ,36EVX*,36HBQ*, 36HBX*-HW,36HBX,36HX,37HX, 37HXX,36HYX,36MBQ**F,36PHYX, 37RAQ,36UC,37UC,36UC-HW, 37UC-HW,36UCQ*,37UCQ*,37UCX, 37UCX-HW,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,
25HBB336C31	34.0	10.80	13.00 ⁽¹⁾⁽²⁾⁽³⁾	36.0	8.20	37CDX-HW,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,36EVB-HW, 36EVBQ,36EVX*,36HBQ*, 36HBX*-HW,36HBX,36HX,37HX, 37HXX,36HYX,36MBQ**F,36PHYX, 37RAQ,36UC,37UC,36UC-HW, 37UC-HW,36UCQ*,37UCQ*,37UCX, 37UCX-HW,37UCXQ*,36VHBQ*, 36VHBX*-HW,36VHBX,
25HBB342(A,W)30	40.5	10.40	13.00 ⁽¹⁾⁽²⁾⁽³⁾	41.5	8.20	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,48HBX*-HW,48HBX, 48HYX,48MBQ**F,48PHYX, 48VHBQ*,48VHBX*-HW,48VHBX,
25HBB342C31	41.5	11.00	13.00 ⁽¹⁾⁽²⁾⁽³⁾	42.0	8.00	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,48HBX*-HW,48HBX, 48HYX,48MBQ**F,48PHYX, 48VHBQ*,48VHBX*-HW,48VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER OUTDOOR UNIT	Cooling			Heating		FIRST CO. INDOOR UNITS
	MBTUH	EER	SEER	MBTUH	HSPF	
25HBB348(A,W)30	47.5	11.00	13.00 ⁽¹⁾⁽²⁾⁽³⁾	48.0	8.00	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,60HBQ*,48HBX*-HW, 60HBX*-HW,48HBX,60HBX,48HYX, 60HYX,60MBQ**F,48PHYX, 60PHYX,48VHBQ*,60VHBQ*, 48VHBX*-HW,60VHBX*-HW, 48VHBX,60VHBX,
25HBB348C31	46.0	11.00	13.00 ⁽²⁾⁽³⁾	46.0	8.00	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,60HBQ*,48HBX*-HW, 60HBX*-HW,48HBX,60HBX,48HYX, 60HYX,60MBQ**F,48PHYX, 60PHYX,48VHBQ*,60VHBQ*, 48VHBX*-HW,60VHBX*-HW, 48VHBX,60VHBX,
25HBB360(A,W)31	58.5	10.80	13.00 ⁽¹⁾⁽²⁾⁽³⁾	58.0	7.70	60HBQ*,60HBX*-HW,60HBX, 60HYX,60PHYX,60VHBQ*, 60VHBX*-HW,60VHBX,
25HBB360C32	60.0	11.00	13.00 ⁽¹⁾⁽²⁾⁽³⁾	60.0	8.00	60HBQ*,60HBX*-HW,60HBX, 60HYX,60PHYX,60VHBQ*, 60VHBX*-HW,60VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.