



CARRIER OUTDOOR UNIT	Cooling			Heating		FIRST CO. INDOOR UNITS
	MBTUH	EER	SEER	MBTUH	HSPF	
*25HCB324A30	23.0	11.00	13.00 <sup>(2)(3)</sup>	23.0	8.00	25CDX-HW,31CDX-HW,25CDXQ, 31CDXQ,24CLP,24CLP-AQ, 24CLP-HW,24CLX,24CLX-AQ, 24CLX-HW,24DFCH,30DFCH, 24EVB-HW,24EVBQ,24EVX*, 24HBQ*,30HBQ*,24HBX*-HW, 30HBX*-HW,24HBX,30HBX,25HX, 30HX,31HX,25HXX,31HXX, 30MBQ**F,25UC,30UC,31UC, 25UC-HW,30UC-HW,31UC-HW, 25UCQ*,30UCQ*,31UCQ*,25UCX, 31UCX,25UCX-HW,31UCX-HW, 25UCXQ*,31UCXQ*,24VHBQ*, 24VHBX*-HW,24VHBX,
*25HCB336A30	34.0	11.00	13.00 <sup>(2)(3)</sup>	34.0	8.00	37CDX-HW,37CDXQ,36CLP, 36CLP-AQ,36CLP-HW,36CLX, 36CLXAQ,36CLX-HW,36EVB-HW, 36EVBQ,36EVX*,36HBQ*, 36HBX*-HW,36HBX,36HX,37HX, 37HXX,36HYX,36MBQ**F,36PHYX, 37RAQ,37UC,37UC-HW,37UCQ*, 37UCX,37UCX-HW,37UCXQ*, 36VHBQ*,36VHBX*-HW,36VHBX,
*25HCB342A30	41.0	11.00	13.00 <sup>(2)(3)</sup>	41.0	8.00	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,48HBX*-HW,48HBX, 48HYX,48MBQ**F,48PHYX, 48VHBQ*,48VHBX*-HW,48VHBX,

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



CARRIER OUTDOOR UNIT	Cooling			Heating		FIRST CO. INDOOR UNITS
	MBTUH	EER	SEER	MBTUH	HSPF	
*25HCB348A30	46.5	11.00	13.00 <sup>(2)(3)</sup>	48.5	8.00	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,60HBQ*,48HBX*-HW, 60HBX*-HW,48HBX,60HBX,48HYX, 60HYX,60MBQ**F,48PHYX, 60PHYX,48VHBQ*,60VHBQ*, 48VHBX*-HW,60VHBX*-HW, 48VHBX,60VHBX,
*25HCB360A31	59.5	10.80	13.00 <sup>(1)(2)(3)</sup>	60.0	8.00	60HBQ*,60HBX*-HW,60HBX, 60HYX,60PHYX,60VHBQ*, 60VHBX*-HW,60VHBX,

(1)Thermal expansion valve required to obtain system rating.

(2)Time delay relay required to obtain system rating.

(3)System refrigerant charge is R-410A.

(\*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.