



RHEEM CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
13AJM18**	19.1	11.40	13.00 ⁽¹⁾⁽³⁾	19CDX-HW,25CDX-HW,19CDXQ, 25CDXQ,24CLP,24CLP-AQ, 24CLP-HW,24CLX,24CLX-AQ, 24CLX-HW,24DFCH,24EVB-HW, 24EVBQ,24EVX*,18HBQ*,24HBQ*, 18HBX*-HW,24HBX*-HW,18HBX, 24HBX,19HX,25HX,19HXX,25HXX, 24MBQ**F,25UC,25UC-HW, 25UCQ*,25UCX,25UCX-HW, 25UCXQ*,24VHBQ*,24VHBX*-HW, 24VHBX,
13AJM24**	23.0	10.95	13.00 ⁽¹⁾⁽³⁾	25CDX-HW,30CDX-HW,31CDX-HW, 25CDXQ,30CDXQ,31CDXQ,24CLP, 24CLP-AQ,24CLP-HW,24CLX, 24CLX-AQ,24CLX-HW,24DFCH, 30DFCH,24EVB-HW,24EVBQ, 24EVX*,24HBQ*,30HBQ*, 24HBX*-HW,30HBX*-HW,24HBX, 30HBX,24HX,25HX,30HX,31HX, 25HXX,31HXX,24MBQ**F, 30MBQ**F,24UC,25UC,30UC,31UC, 24UC-HW,25UC-HW,30UC-HW, 31UC-HW,24UCQ*,25UCQ*, 30UCQ*,31UCQ*,25UCX,31UCX, 25UCX-HW,31UCX-HW,25UCXQ*, 31UCXQ*,24VHBQ*,24VHBX*-HW, 24VHBX,

(1)Thermal expansion valve required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



RHEEM CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
13AJM30**	27.4	11.05	13.00 ⁽¹⁾⁽³⁾	31CDX-HW,37CDX-HW,31CDXQ, 37CDXQ,36CLP,36CLP-AQ, 36CLP-HW,36CLX,36CLXAQ, 36CLX-HW,30DFCH,36EVB-HW, 36EVBQ,36EVX*,30HBQ*,36HBQ*, 30HBX*-HW,36HBX*-HW,30HBX, 36HBX,30HX,31HX,36HX,37HX, 31HXX,37HXX,36HYX,30MBQ**F, 36MBQ**F,36PHYX,37RAQ,31UC, 36UC,37UC,31UC-HW,36UC-HW, 37UC-HW,31UCQ*,36UCQ*, 37UCQ*,31UCX,37UCX,31UCX-HW, 37UCX-HW,31UCXQ*,37UCXQ*, 36VHBQ*,36VHBX*-HW,36VHBX,
13AJM36**	34.2	11.15	13.25 ⁽¹⁾⁽³⁾	36CDX-HW,37CDX-HW,36CDXQ, 37CDXQ,36CLP,36CLP-AQ, 36CLP-HW,36CLX,36CLXAQ, 36CLX-HW,36EVB-HW,36EVBQ, 36EVX*,36HBQ*,36HBX*-HW, 36HBX,36HX,37HX,37HXX,36HYX, 36MBQ**F,36PHYX,37RAQ,36UC, 37UC,36UC-HW,37UC-HW,36UCQ*, 37UCQ*,37UCX,37UCX-HW, 37UCXQ*,36VHBQ*,36VHBX*-HW, 36VHBX,
13AJM42**	41.0	11.05	13.00 ⁽¹⁾⁽³⁾	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,48HBX*-HW,48HBX, 48HYX,48PHYX,48VHBQ*, 48VHBX*-HW,48VHBX,

(1)Thermal expansion valve required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.



RHEEM CONDENSING UNIT	MBTUH	EER	SEER	FIRST CO. EVAPORATOR MODELS
13AJM48**	46.5	11.20	13.00 ⁽¹⁾⁽³⁾	48EVB-HW,48EVBQ,48EVX*, 48HBQ*,60HBQ*,48HBX*-HW, 60HBX*-HW,48HBX,60HBX,48HYX, 60HYX,60MBQ**F,48PHYX, 60PHYX,48VHBQ*,60VHBQ*, 48VHBX*-HW,60VHBX*-HW, 48VHBX,60VHBX,

(1)Thermal expansion valve required to obtain system rating.

(3)System refrigerant charge is R-410A.

(*)Indicates an additional letter in the model number.

First Co. certifies that the capacity and SEER values shown are calculated using the methodology approved by the U.S. Department of Energy as specified in Section 430.23(M) of 10cfr Part 430. The calculation procedure utilizes the test data collected in accordance with ARI Standard 210/240-89 and has been validated by an independent test in accordance with DOE standards.